

LIVEWELL PHARMACY & DOCTOR'S OFFICE
271 RIDGEWAY ROAD, CRYSTAL BEACH

FUNCTIONAL SERVICING DESIGN BRIEF
EXISTING STORM, SANITARY AND WATER SERVICES

REV 2 – February 01, 2023

PREPARED BY:



HALLEX PROJECT #221113

HALLEX NIAGARA
4999 VICTORIA AVENUE
NIAGARA FALLS, ON L2E 4C9

HALLEX HAMILTON
745 SOUTH SERVICE ROAD, UNIT 205
STONEY CREEK, ON L8E 5Z2

TABLE OF CONTENTS

1. INTRODUCTION	1
2. EXISTING MUNICIPAL INFRASTRUCTURE	1
2.1 EXISTING SITE DRAINAGE & STORM SEWER.....	1
2.2 SANITARY SEWER	1
2.3 WATERMAIN	1
3. STORM SEWER/DRAINAGE SYSTEM	2
3.1 PRE-DEVELOPMENT SITE FLOW.....	2
3.2 POST-DEVELOPMENT SITE FLOW	2
3.3 STORMWATER QUANTITY CONTROL.....	2
4. SANITARY SEWER SYSTEM	3
5. WATER DISTRIBUTION SYSTEM	4
6. CONCLUSION	5

PRE-DEVELOPMENT CATCHMENT AREA PLAN

POST-DEVELOPMENT CATCHMENT AREA PLAN

EXHIBITS – Servicing Design Sheets

1. INTRODUCTION

The proposed Livewell Pharmacy & Doctor's Office development consists of the interior renovation of the existing Crystal Beach Fire Station complete with minor site modifications. This development is located at 271 Ridgeway Road, which is west of the Ridgeway Road and Roxborough Ave intersection in the Town of Fort Erie, ON. The subject property also fronts and has access to Cambridge Road East.

The purpose of the service assessment is to determine the functional sizing of the proposed storm, sanitary and water services in addition to the post-development flows from the site to determine the impact on the existing municipal infrastructure.

2. EXISTING MUNICIPAL INFRASTRUCTURE

2.1 EXISTING SITE DRAINAGE & STORM SEWER

The existing site currently drains via overland flow partly to the drainage system at Ridgeway Road and partly to the drainage system at Cambridge Road East. The site also does not appear to be serviced with a storm lateral connection as the roof downspouts discharge to grade. The existing drainage infrastructure at Ridgeway Road consists of a 300mm municipal storm sewer and a 1200mm municipal storm sewer. The existing drainage infrastructure at Cambridge Road East consists of a 300mm municipal storm sewer.

2.2 SANITARY SEWER

The existing site is currently serviced as it consisted of the existing Crystal Beach Fire Station, however the location of the existing sanitary lateral is unknown. The Proctor & Redfern Ltd. Dwg A1-79423-P27, Revision 1, dated January 1982 indicates the sanitary lateral drains towards the sanitary infrastructure at Cambridge Road East. The existing sanitary sewer infrastructure at Cambridge Road East consists of a 250mm municipal sanitary sewer with a 200mm PE Liner. The existing sanitary sewer infrastructure at Ridgeway Road consists of a 300mm municipal sanitary sewer with a 250mm PE Liner.

2.3 WATERMAIN

The existing site is currently serviced as it consisted of the existing Crystal Beach Fire Station, however the location of the existing water service is unknown. The Proctor & Redfern Ltd. Dwg A1-79423-P27, Revision 1, dated January 1982 indicates the water service connects to the watermain infrastructure at Cambridge Road East. The site also consists of a fire hydrant located at the northwest corner of the site. The existing watermain infrastructure at Cambridge Road East consists of a 150mm municipal watermain. The existing watermain infrastructure at Ridgeway Road consists of a 150mm municipal watermain.

3. STORM SEWER/DRAINAGE SYSTEM

3.1 PRE-DEVELOPMENT SITE FLOW

The total drainage area for the subject development is 0.190 hectares with an existing runoff coefficient of 0.84 based on the existing roof, asphalt and grass surfaces. The catchment area plan for the pre-development site condition is provided on Hallex Sketch CSK1, attached.

Utilizing the rationale method ($Q = CiA/360$) and the minimum recommended time of concentration of 10 minutes, the allowable peak flow for the pre-development site is as follows:

	Pre-Development
<u>Storm Event</u>	<u>Storm Flow</u>
5-year Storm	37.8 L/s

These flows are calculated using the Town of Fort Erie intensity-duration-frequency curves. The pre-development flows for the existing site are provided in Exhibit #1 for the five -year storm, attached.

3.2 POST-DEVELOPMENT SITE FLOW

The proposed development includes the interior renovation of the existing Crystal Beach Fire Station complete with minor site modifications. The total drainage for the subject development is 0.190 hectares with a proposed runoff coefficient of 0.78 based on the existing surfaces and the minor site modifications to walkways and sheds. Given the minor site alterations that are proposed, the original drainage intent of overland sheet flow to the street shall be maintained. The catchment area plan for the post-development site condition is provided on Hallex Sketch CSK2, attached.

Utilizing the rationale method ($Q = CiA/360$) and the minimum recommended time of concentration of 10 minutes, the calculated peak flow for the post-development site is as follows:

	Post-Development
<u>Storm Event</u>	<u>Storm Flow</u>
5-year Storm	35.2 L/s

These flows are calculated using the Town of Fort Erie intensity-duration-frequency curves. The post-development flows for the proposed development are provided in Exhibit #2 for the five -year storm, attached.

3.3 STORMWATER QUANTITY CONTROL

The post-development storm water runoff for the subject site will decrease by 2.6 L/s for the five-year storm from the pre-development flow from the site. As such, storm water quantity controls are not proposed for this development and the original drainage intent of overland sheet flow to the street is proposed to be maintained.

4. SANITARY SEWER SYSTEM

Given the proposed Livewell Pharmacy & Doctor's Office development consists of the interior renovation of the existing building complete with minor site modifications, the intent of this analysis is to compare the pre- and post-development sanitary flow rates to determine whether there will be an increase or a decrease in wastewater flows to ensure the existing servicing would be sufficient for the proposed use of the building.

The building development is currently in the concept phase; therefore, the following assumptions based on the architectural drawings are made in carrying out the calculations:

- The existing Crystal Beach Fire Station consists of a fire truck garage which has been denoted as warehouse for the purpose of calculating the daily wastewater flows in accordance with Table 8.2.1.3.B of the Ontario Building Code. The warehouse area of the building consists of 2 water closets and 4 loading bays.
- The remaining area of the existing Crystal Beach Fire Station has been denoted as office for the purposes of calculating the daily wastewater flows in accordance with Table 8.2.1.3.B of the Ontario Building Code. The office area of the building consists of a floor area of 270.7m².
- The proposed Livewell Pharmacy & Doctor's Office has been denoted as doctor's office for the purposes of calculating the daily wastewater flows in accordance with Table 8.2.1.3.B of the Ontario Building Code. The office is assumed to consist of 11 practitioners and 1 employee per 8-hour shift.
- The plumbing fixtures and the number of plumbing fixtures indicated in Exhibit #3 are existing.
- The plumbing fixtures and the number of plumbing fixtures indicated in Exhibit #4 are assumed and may not represent the final building plumbing design.

The peak drainage rate for the Crystal Beach Fire Station is determined to be 177.0 L/min based on the fixtures and the 43.0 fixture units shown in Exhibit #3, attached. Table 7.4.10.5 in the Ontario Building Code is used to determine the probable peak drainage rate for the total fixture units. The wastewater generation is determined to be 4,690 L/day using Table 8.2.1.3B of the O.B.C. as shown in Exhibit #3, attached.

The peak drainage rate for the Livewell Pharmacy & Doctor's Office is determined to be 174.9 L/min based on the fixtures and the 41.5 fixture units shown in Exhibit #4, attached. Table 7.4.10.5 in the Ontario Building Code is used to determine the probable peak drainage rate for the total fixture units. The wastewater generation is determined to be 3,100 L/day using Table 8.2.1.3B of the O.B.C. as shown in Exhibit #4, attached.

The post-development sanitary peak flow for the subject site will decrease by 2.1 L/min from the pre-development sanitary peak flow. Given this reduction in peak flow, the existing sanitary sewer should be sufficiently sized for the development provided it is a minimum 100mm diameter sanitary sewer @ 1.0% as it is capable of a draining a maximum hydraulic load of 180 fixture units as per OBC Table 7.4.10.8. The owner is responsible for having the sewer to be reused video inspected prior to the renovation to confirm the size and condition of the sewer. Should the size be too small or the condition of the pipe is poor, the lateral shall be replaced with a minimum 100mm diameter sanitary sewer @ 1.0%.

5. WATER DISTRIBUTION SYSTEM

Given the proposed Livewell Pharmacy & Doctor's Office development consists of the interior renovation of the existing building complete with minor site modifications, the intent of this analysis is to compare the pre- and post-development water demand rates to determine whether there will be an increase or a decrease in water demands to ensure the existing servicing would be sufficient for the proposed use of the building.

The building development is currently in the concept phase; therefore, the following assumptions based on the architectural drawings are made in carrying out the calculations:

- The plumbing fixtures and the number of plumbing fixtures indicated in Exhibit #5 are existing.
- The plumbing fixtures and the number of plumbing fixtures indicated in Exhibit #6 are assumed and may not represent the final building plumbing design.
- The existing Crystal Beach Fire Station is of non-combustible construction and does not have sprinklers and hose cabinets installed throughout the building.
- The proposed Livewell Medical building will remain of non-combustible construction and will not have sprinklers and hose cabinets installed throughout the building.

The domestic water demand for the Crystal Beach Fire Station is determined to be 170.2 L/min based on the fixtures and the 38.8 fixture units shown in Exhibit #5, attached. Table 7.4.10.5 in the Ontario Building Code is used to determine the water demands for the total fixture units.

The domestic water demand for the Livewell Pharmacy & Doctor's Office is determined to be 167.0 L/min based on the fixtures and the 37.4 fixture units shown in Exhibit #6, attached. Table 7.4.10.5 in the Ontario Building Code is used to determine the water demands for the total fixture units.

The minimum water supply flow rate for fire protection of the Crystal Beach Fire Station is determined to be 5,000 L/min based on the above assumptions as shown in Exhibit #7, attached. The Fire Underwriters Survey – 1999 Water Supply for Public Fire Protection is used to determine the water supply flow rate for the fire protection of the building.

The minimum water supply flow rate for fire protection of the Livewell Pharmacy & Doctor's Office is determined to be 4,000 L/min based on the above assumptions as shown in Exhibit #8, attached. The Fire Underwriters Survey – 1999 Water Supply for Public Fire Protection is used to determine the water supply flow rate for the fire protection of the building.

There are three existing municipal fire hydrants located near the site. The first is located at the northwest corner of the site. The second is located adjacent to the northeast corner of the site on the east side of Ridgeway Road. The third is approximately 30.3m northwest of the property on the westerly corner side of the Essex Place and Cambridge Road East intersection.

The post-development domestic water demand for the subject site will decrease by 3.2 L/min from the pre-development domestic water demand. Given this reduction in water demand, the existing water service should be sufficiently sized for the development provided it is a minimum 25mm diameter water service as it is capable of a draining a maximum hydraulic load of 41 fixture units as per ASHRAE Table A-2.6.1.1.(1). This recommendation is provided assuming a maximum 24.0m water service length and a pressure of 46-60psi in the municipal watermain. Should the size be too small or the condition of the pipe is poor, the lateral shall be replaced with a minimum 25mm diameter water service.

Additionally, the post-development minimum water supply flow rate for fire protection will decrease by 1,000 L/min from the pre-development flow rate. Given this reduction in the minimum water supply flow rate for fire protection, the existing hydrants surrounding the development should provide sufficient coverage for the fire protection of the building.

6. CONCLUSION

The aforementioned calculations and recommendations for the storm, sanitary and water services are based on the current design for the site as of writing this report. A final sealed report, complete with updates to the recommendations made in this report, may be required based on the final site design.

We trust this report meets your approval. Please contact the undersigned should you have any questions or comments.

Yours truly,
HALLEX ENGINEERING LTD




Jim Halucha P.Eng
Civil/Structural Engineer

A handwritten signature in black ink, appearing to read "Jonathan Skinner".

Jonathan Skinner, C.E.T., B.Tech
Civil Technologist




CAMBRIDGE ROAD EAST



RIDGEWAY ROAD

LEGEND



HALLEX
ENGINEERING LTD.

4999 Victoria Avenue,
Niagara Falls, ON L2E 4C9
Tel: 905-357-4015 Fax: 905-353-1105

745 South Service Rd. Unit 205,
Stoney Creek, ON L8E 5Z2
Tel: 905-561-4016 Fax: 905-561-1105

PROJECT:
LIVWELL MEDICAL
271 RIDGEWAY ROAD, CRYSTAL BEACH, ON

SHEET TITLE:
PRE-DEVELOPMENT CATCHMENT AREA PLAN

DATE: 02/01/2023

JOB No.: 221113

SCALE: 1:400

DWG.

REV.

DR. BY: JF


CSK1

1

CH. BY: JS/JH





CAMBRIDGE ROAD EAST



RIDGEWAY ROAD

LEGEND

HALLEX
ENGINEERING LTD.

4999 Victoria Avenue,
Niagara Falls, ON L2E 4C9
Tel: 905-357-4015 Fax: 905-353-1105

745 South Service Rd. Unit 205,
Stoney Creek, ON L8E 5Z2
Tel: 905-561-4016 Fax: 905-561-1105

PROJECT:
LIVEWELL MEDICAL
271 RIDGEWAY ROAD, CRYSTAL BEACH, ON

SHEET TITLE:
POST-DEVELOPMENT CATCHMENT AREA PLAN

DATE: 02/01/2023

JOB No.: 221113

SCALE: 1:400

DWG.

REV.

DR. BY: JF

CH. BY: JS/JH

CSK2

1



Livewell Medical
Exhibit #3 - Pre-Development Wastewater Generation Rate
& Peak Drainage Rate

2/1/2023
 Job: 221113

WASTEWATER GENERATION ASSESSMENT

Occupancy	Development Statistics	Volume (Table 8.2.1.3. A / B)	Total Daily Volume	Notes
Warehouse Water Closets	2 WCs	950 L/WC	1900 L/day	Add water closets & loading bays
Warehouse Loading Bays	4 bays	150 L/bay	600 L/day	Add water closets & loading bays
Office Building Area	29.2 9.3m2s	75 L/9.3m2	2190 L/day	Choose greater of staff & area
Total =			4690 L/day	

Therefore the total calculated sanitary flow from the site is determined to be 4690 L/day.

MAXIMUM PROBABLE DRAINAGE RATE

Fixture	# of Plumbing Fixtures	Fixture Units (Table 7.4.9.3.)	Total Sanitary Fixture Units
Urinal (private, wall washout)	2 fixtures	1.5 FUs	3 FUs
Lavatory (private, domestic)	6 fixtures	1.5 FUs	9 FUs
Water closet w/ flush tank (private)	6 fixtures	4 FUs	24 FUs
Clothes washer (private, domestic)	1 fixture	1.5 FUs	1.5 FUs
Dishwasher (domestic)	1 fixture	1 FUs	1 FUs
Sink (domestic)	1 fixture	1.5 FUs	1.5 FUs
Shower drain (private, 1 head)	2 fixtures	1.5 FUs	3 FUs
Total =			43.0 FUs
Total Flow =			177.0 L/min

Therefore the total calculated peak drainage rate is determined to be 177L/min.



Livewell Medical
Exhibit #4 - Post-Development Wastewater Generation Rate
& Peak Drainage Rate

2/1/2023
 Job: 221113

WASTEWATER GENERATION ASSESSMENT

Occupancy	Development Statistics	Volume (Table 8.2.1.3. A / B)	Total Daily Volume	Notes
Doctors Office Practitioner	11 persons	275 L/person	3025 L/day	Add practitioners & staff
Doctors Office Staff	1 person	75 L/person	75 L/day	Add practitioners & staff
Total =			3100 L/day	

Therefore the total calculated sanitary flow from the site is determined to be 3100 L/day.

MAXIMUM PROBABLE DRAINAGE RATE

Fixture	# of Plumbing Fixtures	Fixture Units (Table 7.4.9.3.)	Total Sanitary Fixture Units
Water closet w/ flush tank (private)	4 fixtures	4 FUs	16 FUs
Lavatory (private, domestic)	4 fixtures	1.5 FUs	6 FUs
Sink (domestic)	2 fixtures	1.5 FUs	3 FUs
Dishwasher (domestic)	1 fixture	1 FUs	1 FUs
Lavatory (dental)	11 fixtures	1 FUs	11 FUs
Shower drain (private, 1 head)	1 fixture	1.5 FUs	1.5 FUs
Sink (service or mop basin)	1 fixture	3 FUs	3 FUs
Total =			41.5 FUs
Total Flow =			174.9 L/min

Therefore the total calculated peak drainage rate is determined to be 174.9L/min.



Livewell Medical
Exhibit #5 - Pre-Development Water Demand

2/1/2023
Job: 221113

DOMESTIC WATER SUPPLY

Fixture	# of Plumbing Fixtures	Fixture Units (Table 7.6.3.2.A.)	Total Water Fixture Units
Urinal (private, wall washout)	2 fixtures	3 FUs	6 FUs
Lavatory (private, domestic)	6 fixtures	1 FUs	6 FUs
Water closet w/ flush tank (private)	6 fixtures	3 FUs	18 FUs
Clothes washer (private, domestic)	1 fixture	1.4 FUs	1.4 FUs
Dishwasher (domestic)	1 fixture	1.4 FUs	1.4 FUs
Sink (domestic)	1 fixture	2 FUs	2 FUs
Shower drain (private, 1 head)	2 fixtures	2 FUs	4 FUs
Total =			38.8 FUs
Total Flow =			170.2 L/min

Therefore the maximum domestic water demand is determined to be 170.2 L/min.



Livewell Medical
Exhibit #6 - Post-Development Water Demand

2/1/2023
Job: 221113

DOMESTIC WATER SUPPLY

Fixture	# of Plumbing Fixtures	Fixture Units (Table 7.6.3.2.A.)	Total Water Fixture Units
Water closet w/ flush tank (private)	4 fixtures	3 FUs	12 FUs
Lavatory (private, domestic)	4 fixtures	1 FUs	4 FUs
Sink (domestic)	2 fixtures	2 FUs	4 FUs
Dishwasher (domestic)	1 fixture	1.4 FUs	1.4 FUs
Lavatory (dental)	11 fixtures	1 FUs	11 FUs
Shower drain (private, 1 head)	1 fixture	2 FUs	2 FUs
Sink (service or mop basin)	1 fixture	3 FUs	3 FUs
Total =			37.4 FUs
Total Flow =			167.0 L/min

Therefore the maximum domestic water demand is determined to be 167 L/min.

