



## Fort Erie Distribution System

### Summary Report for July 2022

#### Chlorine (free)

# samples:	123	min:	0.31	mg/L
# detects:	123	max:	1.12	mg/L
# non-detects:	0	avg:	0.72	mg/L (based on 123 numerical results)
# exceedances:	0			

#### Escherichia coli / E. coli (counts)

# samples:	55	min:	0	counts/100ml
# detects:	55	max:	0	counts/100ml
# non-detects:	0	Geometric Mean:	0	counts/100ml (based on 51 numerical results)
# exceedances:	1			

#### Total coliforms (counts)

# samples:	55	min:	0	counts/100ml
# detects:	55	max:	1	counts/100ml
# non-detects:	0	Geometric Mean:	1	counts/100ml (based on 51 numerical results)
# exceedances:	2			

#### Heterotrophic Plate Count / HPC

# samples:	55	min:	0	CFU/ml
# detects:	55	max:	90	CFU/ml
# non-detects:	0	Geometric Mean:	2	CFU/ml (based on 52 numerical results)
# exceedances:	0			

#### Alkalinity (total, as CaCO<sub>3</sub>)

# samples:	4	min:	90	mg/L
# detects:	4	max:	93	mg/L
# non-detects:	0	avg:	91	mg/L (based on 4 numerical results)
# exceedances:	0			

P=present, A=absent, PR=presumptive, ND=non-detect, U=non-detect, OR=over-range, OG=overgrown,  
 TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment  
 cfu= colony forming units  
 < means less than lower detection limit shown  
 > means greater than upper detection limit shown  
 « means detected & less than number shown  
 » means detected & greater than number shown  
 \* Indicates Criteria is exceeded