



Fort Erie Distribution System

Summary Report for September 2021

Chlorine (free)

# samples:	216	min:	0.13	mg/L
# detects:	216	max:	1.31	mg/L
# non-detects:	0	avg:	0.73	mg/L (based on 216 numerical results)
# exceedances:	0			

Escherichia coli / E. coli (counts)

# samples:	45	min:	0	counts/100ml
# detects:	45	max:	0	counts/100ml
# non-detects:	0	Geometric Mean:	0	counts/100ml (based on 45 numerical results)
# exceedances:	0			

Total coliforms (counts)

# samples:	45	min:	0	counts/100ml
# detects:	45	max:	7	counts/100ml
# non-detects:	0	Geometric Mean:	1	counts/100ml (based on 45 numerical results)
# exceedances:	1			

Heterotrophic Plate Count / HPC

# samples:	45	min:	0	CFU/ml
# detects:	45	max:	6	CFU/ml
# non-detects:	0	Geometric Mean:	2	CFU/ml (based on 45 numerical results)
# exceedances:	0			

Total Trihalomethanes / TTHM

# samples:	3	min:	0.0471	mg/L
# detects:	3	max:	0.0525	mg/L
# non-detects:	0	avg:	0.0493	mg/L (based on 3 numerical results)
# exceedances:	0			

Haloacetic acids 5 / HAA5

# samples:	3	min:	0.0036	mg/L
# detects:	3	max:	0.0071	mg/L
# non-detects:	0	avg:	0.0048	mg/L (based on 3 numerical results)
# exceedances:	0			

P=present, A=absent, PR=presumptive, ND=non-detect, U=non-detect, OR=over-range, OG=overgrown,
 TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

cfu= colony forming units

< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

* Indicates Criteria is exceeded