



Fort Erie Distribution System

Summary Report for February 2022

Chlorine (free)

# samples:	115	min:	0.25	mg/L
# detects:	115	max:	1.14	mg/L
# non-detects:	0	avg:	0.86	mg/L (based on 115 numerical results)
# exceedances:	0			

Escherichia coli / E. coli (counts)

# samples:	43	min:	0	counts/100ml
# detects:	43	max:	0	counts/100ml
# non-detects:	0	Geometric Mean:	0	counts/100ml (based on 43 numerical results)
# exceedances:	0			

Total coliforms (counts)

# samples:	43	min:	0	counts/100ml
# detects:	43	max:	0	counts/100ml
# non-detects:	0	Geometric Mean:	0	counts/100ml (based on 43 numerical results)
# exceedances:	0			

Heterotrophic Plate Count / HPC

# samples:	43	min:	0	CFU/ml
# detects:	43	max:	6	CFU/ml
# non-detects:	0	Geometric Mean:	1	CFU/ml (based on 43 numerical results)
# exceedances:	0			

P=present, A=absent, PR=presumptive, ND=non-detect, U=non-detect, OR=over-range, OG=overgrown,
 TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment
 cfu= colony forming units
 < means less than lower detection limit shown
 > means greater than upper detection limit shown
 « means detected & less than number shown
 » means detected & greater than number shown
 * Indicates Criteria is exceeded